

Product Safety Recall

Mack & Lanson Branded Combination RCD & MCB (RCBO)

Part No.'s MRR-H10C, MRR-H16C, MRR-H-20C, MRRH-25C, MRRH-32C and LANRCBO610SA, LANRCBO616SA LANRCBO620SA, LANRCBO625SA LANRCBO632SA sold from Electrical Wholesalers through the period 16/09/2010 to 5/11/2010.

Defect: The product fails the 6Ka short circuit test.

Hazard: Following a rare high fault current event at full rated capacity, the RCBO may pose an electrical shock risk.

What to do: Contact Electrical Product systems to arrange to have the items replaced. Electrical Product Systems will liaise with you as to the installation costs, return of the faulty products along with receipt of a Certificate of Electrical Safety (or equivalent depending on the requirements of the Electrical Authority in your area) to demonstrate the items have been installed. On completion, the relevant electrical authorities will be advised and the faulty items destroyed.

Contact Details: Contact "Electrical Product Systems" via the internet at www.rcborecall.com.au or alternatively contact by phone on 03 9862 4234.

Items bought
between 16/09/2010
to 5/11/2010.

